Results for the 8'x100' circular tank with ramp:

Circular tank:

Tank Diameter = 100 ft
Tank Wall thickness = 8 in (actual)
Tank Height = 8 ft
f_y= 60,000 psi
f'_c = 4,000 psi

Horizontal Steel = #4 rebar		
Bar #	Spacing (in)	Distance from finished floor (ft - in)
1	3	0' 3"
2	12	1' 3"
3	12	2' 3"
4	12	3' 3"
5	12	4' 3"
6	12	5' 3"
7	10	6' 1"
8	10	6' 11"
9	10	7' 9"

Vertical Steel shall be #4 @ 12" O.C.
Dowels "L" bars shall be #4 @ 12" O.C. with a horizontal leg of 6" and a vertical leg of 26"

In the tank wall, at the notch for the ramp add:
3-#6 bars x 11'-10" long @ 4" O.C. vertically.
3-#6 bars x 20' long @ 4" O.C. horizontally.
4-#6 bars x 6 feet long @ 4" O.C. at a 45 degree angle.